



DJ Micky NE Entertainments
 3 Bakers Gardens
 Dunston
 NE11 9HA

CMD Pat Testing
 9 Middlefield
 Pelton
 DH2 1DP

Test Date : 20/07/2023

Tel : 07861 688 388
 info@cmdpattesting.co.uk

PAT Serial Number : E007031
 Tested By : CD

APP ID	Description	Location	Class	Visual	Earth (Ω)	Insulation	Leakage (mA)	Result	Notes
15122	SPEAKER	MOBILE	I	Pass	0.01	>20.00	0.32	Pass	
15123	SPEAKER	MOBILE	I	Pass	0.01	>20.00	0.04	Pass	
15124	SPEAKER	MOBILE	I	Pass	0.01	>20.00	0.04	Pass	
15125	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	1.04	Pass	
15126	DJ LIGHT	MOBILE	II	Pass		>20.00	1.02	Pass	
15127	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	0.55	Pass	
15128	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	0.91	Pass	
15129	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	0.86	Pass	
15130	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	0.75	Pass	
15131	DJ LIGHT	MOBILE	I	Pass	0.01	>20.00	0.7	Pass	
15132	MIXER	MOBILE	I	Pass	0.01	>20.00	0.05	Pass	
15133	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15134	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15135	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15136	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15137	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15138	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15139	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15140	IEC LEAD	MOBILE	I	Pass	0.01	>20.00		Pass	
15141	EXT 4 WAY	MOBILE	I	Pass	0.01	>20.00		Pass	

15142	EXT 3 WAY	MOBILE	I	Pass	0.01	>20.00	Pass
15143	EXT 6 WAY	MOBILE	I	Pass	0.01	>20.00	Pass
15144	EXT 3 WAY	MOBILE	I	Pass	0.01	>20.00	Pass
15145	EXT 2 WAY	MOBILE	I	Pass	0.01	>20.00	Pass